

The Corporation of The

Town of Amherstburg

Fire Department





ALL SHORT TERM RENTALS REQUIRE

MAINTENANCE DOCUMENTATION

Ongoing 2 Year Records Upon Request

INTERCONNECTED SMOKE ALARMS

- All Levels
- Each Bedroom
- Dedicated Service Room

CARBON MONOXIDE ALARMS OUTSIDE ALL SLEEPING AREAS

 Outside All Sleeping Areas if Building has Attached Garage and/or Fuel Burning Appliances

2A10BC EXTINGUISHER

All Levels at Exits

FIREPLACE/CHIMNEY/APPLIANCES ANNUAL MAINTENANCE

- All Fuel Burning Appliances; Furnace, Hot Water, Fireplace, Wood Stove
- Fire Department Maintenance Requirement Sign Off

MAINTENANCE OF EXITS

- All Exits
- Signage Over Each Exit
- Exits Are Unobstructed Inside and Outside The Suite
- Emergency Window Exits Shall Have Window Opening Instructions Posted At The Window

APPROVED FIRE SAFETY PLAN (FSP)

 Required for Each Unit and Must be Submitted to Fire Service for Review and Approval

Phone:

Fax:

519-736-6500

519-736-3683

Email: mmio@amherstburg.ca

• FSP Must Include Floor Plans for Each Level and Parking Plan if Applicable

FLOOR PLANS

- Floor Plans for Each Level Must Have a Legend and Indicates Placement of:
 - a. Smoke/Carbon Monoxide Alarms
 - b. Smoke Alarms
 - c. Fire Extinguishers
 - d. EXIT Signs & Emergency Lighting
 - e. Secondary Means of Egress
 - f. Main Electrical Shut Off
 - g. Main Gas Shut Off
 - h. Mechanical Room Location

APPROVED SECOND EXIT BASEMENT

- Approved Second Exit from Basement if Sleeping Below Grade
 - i. Basement Y/N

SHORT TERM RENTALS 5 BEDROOMS OR GREATER ALSO REQUIRE

EMERGENCY CORRIDOR LIGHTING

- All Corridors
- Stairways

APPROVED SECOND EXIT

- Approved Second Exit from:
 - i. First Floor Y/N
 - ii. Second Floor Y/N
 - iii. Third Floor Y/N

EXIT SIGNAGE

- All Corridors (Exit sign meets OBC requirements for size, colour and either hardwired or photoluminescent
- Ensure the exit signage meets CAN/ULC S-572 Standard for Photoluminescent signage

SHORT TERM RENTALS 7 BEDROOMS OR GREATER ALSO REQUIRE

FIRE ALARM SYSTEM

- All Corridors (Exit sign meets OBC requirements for size, colour and either hardwired or photoluminescent (photoluminescent also requires constant light source or emergency light pack directed at sign))
- Ensure the exit signage meets CAN/ULC S-572 Standard for Photoluminescent signage